



State of Louisiana
Louisiana Department of Health
Public Health Laboratories
104 North First Street
Amite, LA 70422
985-748-2011
<http://www.dhh.la.gov/lab>



April 06, 2021

The following analytical results have been obtained for the indicated sample(s) which was submitted to this laboratory:

Public Water System:	LA1103053	Sample ID:	A2102104-001
	ST TAM PARISH - CROSS GATES SD	Sample type:	Routine
PWS facility:	DS0950	DISTRIBUTION SYSTEM	
Sampling location:	TCR-005	321 AUTUMN LAKES ROAD	
Collection address:			
Free chlorine (mg/L):		Sample collector:	LAQUANDA JACKSON
Total chlorine (mg/L):	1.12	Collection date:	4/5/2021 12:02:00PM
		Lab submittal date:	4/5/2021 2:05:00PM

Component Name	Results	Units	MCL
Coliforms - Presence/Absence			
Total Coliform	Absent	N/A	N/A
E. Coli	Absent	N/A	N/A

Public Water System:	LA1103053	Sample ID:	A2102104-002
	ST TAM PARISH - CROSS GATES SD	Sample type:	Routine
PWS facility:	DS0950	DISTRIBUTION SYSTEM	
Sampling location:	TCR-006	1301 BLUFF DR.	
Collection address:			
Free chlorine (mg/L):		Sample collector:	LAQUANDA JACKSON
Total chlorine (mg/L):	1.83	Collection date:	4/5/2021 11:48:00AM
		Lab submittal date:	4/5/2021 2:05:00PM

Component Name	Results	Units	MCL
Coliforms - Presence/Absence			
Total Coliform	Absent	N/A	N/A
E. Coli	Absent	N/A	N/A

Public Water System:	LA1103053 ST TAM PARISH - CROSS GATES SD	Sample ID:	A2102104-003
PWS facility:	DS0950 DISTRIBUTION SYSTEM	Sample type:	Routine
Sampling location:	TCR-009 575 WINBOURNE DR.	Sample collector:	LAQUANDA JACKSON
Collection address:		Collection date:	4/5/2021 11:30:00AM
Free chlorine (mg/L):		Lab submittal date:	4/5/2021 2:05:00PM
Total chlorine (mg/L):	1.61		

Component Name	Results	Units	MCL
Coliforms - Presence/Absence			
Total Coliform	Absent	N/A	N/A
E. Coli	Absent	N/A	N/A

Public Water System:	LA1103053 ST TAM PARISH - CROSS GATES SD	Sample ID:	A2102104-004
PWS facility:	DS0950 DISTRIBUTION SYSTEM	Sample type:	Routine
Sampling location:	TCR-015 126 LARCHWOOD DR.	Sample collector:	LAQUANDA JACKSON
Collection address:		Collection date:	4/5/2021 12:35:00PM
Free chlorine (mg/L):		Lab submittal date:	4/5/2021 2:05:00PM
Total chlorine (mg/L):	1.60		

Component Name	Results	Units	MCL
Coliforms - Presence/Absence			
Total Coliform	Absent	N/A	N/A
E. Coli	Absent	N/A	N/A

Public Water System:	LA1103053 ST TAM PARISH - CROSS GATES SD	Sample ID:	A2102104-005
PWS facility:	DS0950 DISTRIBUTION SYSTEM	Sample type:	Routine
Sampling location:	TCR-016 870 CROSSGATES BLVD.	Sample collector:	LAQUANDA JACKSON
Collection address:		Collection date:	4/5/2021 12:17:00PM
Free chlorine (mg/L):		Lab submittal date:	4/5/2021 2:05:00PM
Total chlorine (mg/L):	1.55		

Component Name	Results	Units	MCL
Coliforms - Presence/Absence			
Total Coliform	Absent	N/A	N/A
E. Coli	Absent	N/A	N/A

Reviewed by: Dat Ngo