



State of Louisiana
Louisiana Department of Health
Public Health Laboratories
104 North First Street
Amite, LA 70422
985-748-2011
<http://www.dhh.la.gov/lab>



April 06, 2021

The following analytical results have been obtained for the indicated sample(s) which was submitted to this laboratory:

Public Water System:	LA1103053 ST TAM PARISH - CROSS GATES SD	Sample ID:	A2102703-001
PWS facility:		Sample type:	Investigational
Sampling location:		Sample collector:	Fernando Davis
Collection address:	915 Crossgates Blvd	Collection date:	4/5/2021 9:52:00AM
Free chlorine (mg/L):	0.00	Lab submittal date:	4/5/2021 12:42:39PM
Total chlorine (mg/L):	1.46		

Component Name	Results	Units	MCL
Coliforms - Presence/Absence			
Total Coliform	Absent	N/A	N/A
E. Coli	Absent	N/A	N/A

Public Water System:	LA1103053 ST TAM PARISH - CROSS GATES SD	Sample ID:	A2102703-002
PWS facility:		Sample type:	Investigational
Sampling location:		Sample collector:	Fernando Davis
Collection address:	2301 Gause Blvd E	Collection date:	4/5/2021 10:21:00AM
Free chlorine (mg/L):	0.22	Lab submittal date:	4/5/2021 12:42:39PM
Total chlorine (mg/L):	1.80		

Component Name	Results	Units	MCL
Coliforms - Presence/Absence			
Total Coliform	Absent	N/A	N/A
E. Coli	Absent	N/A	N/A

Public Water System: LA1103053
ST TAM PARISH - CROSS GATES SD

PWS facility:
Sampling location:
Collection address: 101 S Military Rd.
Free chlorine (mg/L): 0.18
Total chlorine (mg/L): 1.57

Sample ID: A2102703-003
Sample type: Investigational
Sample collector: Fernando Davis
Collection date: 4/5/2021 11:18:00AM
Lab submittal date: 4/5/2021 12:42:39PM

Component Name	Results	Units	MCL
Coliforms - Presence/Absence			
Total Coliform	Absent	N/A	N/A
E. Coli	Absent	N/A	N/A

Reviewed by: Dat Ngo