



State of Louisiana
Louisiana Department of Health
Public Health Laboratories
104 North First Street
Amite, LA 70422
985-748-2011
<http://www.dhh.la.gov/lab>



April 16, 2021

The following analytical results have been obtained for the indicated sample(s) which was submitted to this laboratory:

Public Water System:	LA1103053	Sample ID:	A2102968-001
	ST TAM PARISH - CROSS GATES SD	Sample type:	Investigational
PWS facility:	DS0950	DISTRIBUTION SYSTEM	
Sampling location:	TCR-007	1059 PARKPOINT DR.	
Collection address:			
Free chlorine (mg/L):		Collection date:	4/15/2021 3:24:00PM
Total chlorine (mg/L):	1.17	Lab submittal date:	4/15/2021 5:15:00PM

Component Name	Results	Units	MCL
Coliforms - Presence/Absence			
Total Coliform	Absent	N/A	N/A
E. Coli	Absent	N/A	N/A

Public Water System:	LA1103053	Sample ID:	A2102968-002
	ST TAM PARISH - CROSS GATES SD	Sample type:	Investigational
PWS facility:	DS0950	DISTRIBUTION SYSTEM	
Sampling location:	TCR-014	102 CEDARWOOD DR.	
Collection address:			
Free chlorine (mg/L):		Collection date:	4/15/2021 3:33:00PM
Total chlorine (mg/L):	1.43	Lab submittal date:	4/15/2021 5:15:00PM

Component Name	Results	Units	MCL
Coliforms - Presence/Absence			
Total Coliform	Absent	N/A	N/A
E. Coli	Absent	N/A	N/A

Public Water System:	LA1103053 ST TAM PARISH - CROSS GATES SD	Sample ID:	A2102968-003
PWS facility:	DS0950 DISTRIBUTION SYSTEM	Sample type:	Investigational
Sampling location:	TCR-015 126 LARCHWOOD DR.	Sample collector:	Aaron Davis
Collection address:		Collection date:	4/15/2021 3:20:00PM
Free chlorine (mg/L):	0.09	Lab submittal date:	4/15/2021 5:15:00PM
Total chlorine (mg/L):	1.34		

Component Name	Results	Units	MCL
Coliforms - Presence/Absence			
Total Coliform	Absent	N/A	N/A
E. Coli	Absent	N/A	N/A

Public Water System:	LA1103053 ST TAM PARISH - CROSS GATES SD	Sample ID:	A2102968-004
PWS facility:		Sample type:	Investigational
Sampling location:		Sample collector:	Fernando Davis
Collection address:	1043 Park Point Dr	Collection date:	4/15/2021 3:12:00PM
Free chlorine (mg/L):		Lab submittal date:	4/15/2021 5:15:00PM
Total chlorine (mg/L):	1.18		

Component Name	Results	Units	MCL
Coliforms - Presence/Absence			
Total Coliform	Absent	N/A	N/A
E. Coli	Absent	N/A	N/A

Public Water System:	LA1103053 ST TAM PARISH - CROSS GATES SD	Sample ID:	A2102968-005
PWS facility:		Sample type:	Investigational
Sampling location:		Sample collector:	Fernando Davis
Collection address:	101 S. Military Rd	Collection date:	4/15/2021 3:38:00PM
Free chlorine (mg/L):		Lab submittal date:	4/15/2021 5:15:00PM
Total chlorine (mg/L):	1.53		

Component Name	Results	Units	MCL
Coliforms - Presence/Absence			
Total Coliform	Absent	N/A	N/A
E. Coli	Absent	N/A	N/A

Public Water System: LA1103053
ST TAM PARISH - CROSS GATES SD
PWS facility:
Sampling location:
Collection address: POE-001 Steele Rd Well
Free chlorine (mg/L):
Total chlorine (mg/L): 1.88

Sample ID: A2102968-006
Sample type: Investigational
Sample collector: Sidney Rodrigue
Collection date: 4/15/2021 2:53:00PM
Lab submittal date: 4/15/2021 5:15:00PM

Component Name	Results	Units	MCL
Coliforms - Presence/Absence			
Total Coliform	Absent	N/A	N/A
E. Coli	Absent	N/A	N/A

Public Water System: LA1103053
ST TAM PARISH - CROSS GATES SD
PWS facility:
Sampling location:
Collection address: ACR-018 201 Leeds Dr.
Free chlorine (mg/L):
Total chlorine (mg/L): 1.23

Sample ID: A2102968-007
Sample type: Investigational
Sample collector: Sidney Rodrigue
Collection date: 4/15/2021 3:04:00PM
Lab submittal date: 4/15/2021 5:15:00PM

Component Name	Results	Units	MCL
Coliforms - Presence/Absence			
Total Coliform	Absent	N/A	N/A
E. Coli	Absent	N/A	N/A

Public Water System: LA1103053
ST TAM PARISH - CROSS GATES SD
PWS facility:
Sampling location:
Collection address: ACR-019 101 Oak Leaf
Free chlorine (mg/L):
Total chlorine (mg/L): 1.56

Sample ID: A2102968-008
Sample type: Investigational
Sample collector: Sidney Rodrigue
Collection date: 4/15/2021 3:20:00PM
Lab submittal date: 4/15/2021 5:15:00PM

Component Name	Results	Units	MCL
Coliforms - Presence/Absence			
Total Coliform	Absent	N/A	N/A
E. Coli	Absent	N/A	N/A

Public Water System: LA1103053
ST TAM PARISH - CROSS GATES SD
PWS facility:
Sampling location:
Collection address: ACR-020 548 Crossgates
Free chlorine (mg/L):
Total chlorine (mg/L): 1.67

Sample ID: A2102968-009
Sample type: Investigational
Sample collector: Sidney Rodrigue
Collection date: 4/15/2021 3:30:00PM
Lab submittal date: 4/15/2021 5:15:00PM

Component Name	Results	Units	MCL
Coliforms - Presence/Absence			
Total Coliform	Absent	N/A	N/A
E. Coli	Absent	N/A	N/A

Public Water System: LA1103053
ST TAM PARISH - CROSS GATES SD
PWS facility:
Sampling location:
Collection address: 1301 Bluff Dr.
Free chlorine (mg/L):
Total chlorine (mg/L): 1.12

Sample ID: A2102968-010
Sample type: Investigational
Sample collector: Chad Freeman
Collection date: 4/15/2021 3:10:00PM
Lab submittal date: 4/15/2021 5:15:00PM

Component Name	Results	Units	MCL
Coliforms - Presence/Absence			
Total Coliform	Absent	N/A	N/A
E. Coli	Absent	N/A	N/A

Public Water System: LA1103053
ST TAM PARISH - CROSS GATES SD
PWS facility:
Sampling location:
Collection address: 500 Dockside Dr
Free chlorine (mg/L):
Total chlorine (mg/L): 1.84

Sample ID: A2102968-011
Sample type: Investigational
Sample collector: Chad Freeman
Collection date: 4/15/2021 3:27:00PM
Lab submittal date: 4/15/2021 5:15:00PM

Component Name	Results	Units	MCL
Coliforms - Presence/Absence			
Total Coliform	Absent	N/A	N/A
E. Coli	Absent	N/A	N/A

Public Water System: LA1103053
ST TAM PARISH - CROSS GATES SD

Sample ID: A2102968-012
Sample type: Investigational
Sample collector: Chad Freeman
Collection date: 4/15/2021 3:39:00PM
Lab submittal date: 4/15/2021 5:15:00PM

PWS facility:
Sampling location:
Collection address: 701 Wood Duck Dr
Free chlorine (mg/L):
Total chlorine (mg/L): 1.61

Component Name	Results	Units	MCL
Coliforms - Presence/Absence			
Total Coliform	Absent	N/A	N/A
E. Coli	Absent	N/A	N/A

Reviewed by: Lisa Carrier